

FRONTLINE FALL PROTECTION TEST REPORT

SCOPE OF WORKS

Data Only – Testing in reference to General Industries OSHA 1926.105(b) / 1910.29(b)

REPORT NUMBER

105226330CRT-001

ISSUE DATE

10/26/2022

PAGES

5

DOCUMENT CONTROL NUMBER

GFT-OP-10a (6-March-2017)

© 2017 INTERTEK





Total Quality. Assured.

3933 US Route 11
Cortland, New York ,USA
13045
Telephone: 607-758-6246
Facsimile: NA
www.intertek.com

TEST REPORT FOR FRONTLINE FALL PROTECTION

Report No.: 105226330CRT-001
Date: October 26, 2022

FRONTLINE FALL PROTECTION

Ph: +1 (888) 523-1795

Andres Betancourt
2023 NW 84th Ave
Miami, FL 33122
USA
andres@frontlinefall.com

Report Number..... : 105226330CRT-001
Signed Quote Number..... : QU-01306255-0
PO Number..... N/A

Name of Testing Laboratory
Preparing the Report : Intertek Testing Services NA Inc.

Test Specification:
Standard..... : N/A
Date(s) of Testing..... : 10/14/2022-10/18/2022

Product Description:
Product Type: : Guard Rail System
Brand Name: : Frontline
Model Number(s): : GUS10
Date(s) Samples Received : 10/12/2022

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Date: October 26, 2022



SECTION 1

SUMMARY OF TESTING

TESTS COMPLETED	TEST SECTION	STATUS
Static Strength Test 200lb (890N Applied outward/downward direction any a point along top edge)	1926.105 (b)	See Results

SECTION 2

This test report concludes the work anticipated in the testing phase of your project. If there are any questions regarding this report, please contact the undersigned at 607-753-6711.

COMPLETED BY:	Steve Morey	REVIEWED BY:	Matthew Stevens
TITLE:	Technician	TITLE:	Team Leader
SIGNATURE:		SIGNATURE	
DATE	10/24/2022	DATE:	10/26/2022

Please see attached test data for detail.

SECTION 3

TESTING EQUIPMENT CALIBRATION INFORMATION

USED FOR TEST	DESCRIPTION	MANUFACTURER	CONTROL NO.	MODEL NO.	SERIAL NO.	CAL. DATE	CAL. DUE
X	Load Cell	Interface	L099	-	-	11/11/21	11/11/22
X	Tape Measure	Stanley	N1407	-	-	2/16/22	2/16/23

Date: October 26, 2022

SECTION 3

SUPPLEMENTAL TEST DATA

OSHA 1926.105 (B)	Static Strength Test for Guard Rails 200lb (890N) :			
	A. <u>Pull outward direction Hold at 200lbs.</u>			
	B. <u>Pull at downward direction Hold at 200 lbs (890N)</u>			
	C. <u>Shall not deflect to a height less than 39 inches</u>			
	Static Strength Requirements			
	Anchorage resist the test load?			
Height Maintain Greater than 39 inches?				
SAMPLE 3				
SAMPLE 4				
SAMPLE 5				
YES				
YES				
YES				
Downward Position				
Static Strength Requirements				
Anchorage resist the test load?				
Height Maintain Greater than 39 inches?				
SAMPLE 3				
SAMPLE 4				
SAMPLE 5				
YES				
YES				
YES				

SECTION 5


REVISION HISTORY

REPORT NUMBER	DATE OF REVISION	DESCRIPTION OF CHANGE:	PROJECT OWNER	REVIEWED BY
105226330CRT-001	10/24/2022	Original Report	Steve Morey	Matthew Stevens
105226330CRT-001	10/26/2022	Revised per Client Email 10/26/22	Steve Morey	Matthew Stevens

Date: October 26, 2022

SECTION 6
PHOTOGRAPHS

Client Provided Image(s)



Date: October 26, 2022

SECTION 6

PHOTOGRAPHS (Continued)

Testing Image(s)

