intertek
Total Quality. Assured.

FRONTLINE FALL PROTECTION INC

TEST REPORT

SCOPE OF WORKs
Client Specified Testing Referencing OSHA 1926.502(b)(3)

REPORT NUMBER
106559921CRT-002

ISSUE DATE
May 15, 2026

PAGES
5



DOCUMENT CONTROL NUMBER
GFT-OP-10a (6-March-2017)
© 2017 INTERTEK

3933 US Route 11
Cortland, New York ,USA
13045
Telephone: 607-758-6246
Facsimile: NA
www.intertek.com

TEST REPORT FOR FRONTLINE FALL PROTECTION LLC
Report No.: 106559921CRT-002
Date: May 15, 2026

Andres Betancourt
Frontline Fall Protection Inc
6 Lee Blvd Malvern, PA 19355
USA
andres@frontlinefall.com

Phone: +1 (888)-523-1795

Report Number..... : 106559921CRT-002

Signed Quote Number..... : Qu-01579394

PO Number.....: N/A

Name of Testing Laboratory
Preparing the Report .....: Intertek Testing Services NA Inc.

Test Specification:

Standard.....: Client Specified Testing

Date(s) of Testing.....: 05/12/2026 – 05/13/2026

Product Description:

Product Type: .....: Guardrail System

Brand Name: .....: Frontline Fall Protection Inc

Model Number(s): .....: TRG10 Trench Guardrail System

Model Sharing .....: N/A

Date(s) Samples Received .....: N/A

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

SECTION 1
SUMMARY OF TESTING

TESTS COMPLETED	STATUS
Client Specified Testing Referencing – OSHA 1926.502(b)(3)	SEE RESULTS

SECTION 2
This test report concludes the work anticipated in the testing phase of your project. If there are any questions regarding this report please contact the undersigned at 607-753-6711.

COMPLETED BY:	Alex Smith	**REVIEWED BY:**	Matthew Stevens
TITLE:	Technician	**TITLE:**	Team Leader
SIGNATURE:		**SIGNATURE**	
DATE	05/14/2026	**DATE:**	05/15/2026

Please see attached test data for details.

SECTION 3
TESTING EQUIPMENT CALIBRATION INFORMATION

USED FOR TEST	DESCRIPTION	MANUFACTURER	CONTROL NO.	MODEL NO.	SERIAL NO.	CAL. DATE	CAL. DUE
X	Load Cell	Interface	L137	-	-	07/16/25	07/16/26

SECTION 4
SUPPLEMENTAL TEST DATA

<table>
<tr><th>SECTION (TEST)</th><th>REQUIREMENT</th><th>RESULTS</th></tr>
<tr><td>Client Specified Testing Referencing:
OSHA 1926.502(b)(3)</td><td>Guardrail systems shall be capable of withstanding, without failure, a force of at least 200 pounds (890 N) applied within 2 inches (5.1 cm) of the top edge, in any outward or downward direction, at any point along the top edge.</td><td>
<table>
<tr><th>Test Requirements:</th><th>Results:</th></tr>
<tr><td>Did Sample withstand a force of 200lbs applied in a outward direction without tipping over?</td><td>YES</td></tr>
<tr><td>Did Sample withstand a force of 200lbs applied in a downward direction without tipping over?</td><td>YES</td></tr>
</table>
</td></tr>
</table>

SECTION 5
REVISION HISTORY

REPORT NUMBER	DATE OF REVISION	DESCRIPTION OF CHANGE:	PROJECT OWNER	REVIEWED BY
106559921CRT-002	05/15/2026	Original Report	Alex Smith	Matthew Stevens

SECTION 6
PHOTOGRAPH



Note:
Sample tested is photographed (Yellow Guardrail).