

# FRONTLINE FALL PROTECTION INC

## TEST REPORT

**SCOPE OF WORKS**

Client Specified Testing Referencing OSHA 1926.502(b)(3)

**REPORT NUMBER**

106559921CRT-002

**ISSUE DATE**

May 15, 2026

**PAGES**

5

**DOCUMENT CONTROL NUMBER**

GFT-OP-10a (6-March-2017)

© 2017 INTERTEK





Total Quality. Assured.

**TEST REPORT FOR FRONTLINE FALL PROTECTION LLC**

Report No.: 106559921CRT-002

Date: May 15, 2026

3933 US Route 11  
Cortland, New York ,USA  
13045  
Telephone: 607-758-6246  
Facsimile: NA  
www.intertek.com

Andres Betancourt  
Frontline Fall Protection Inc  
6 Lee Blvd Malvern, PA 19355  
USA  
[andres@frontlinefall.com](mailto:andres@frontlinefall.com)

Phone: +1 (888)-523-1795

**Report Number**..... : 106559921CRT-002

**Signed Quote Number**..... : Qu-01579394

**PO Number**.....: N/A

**Name of Testing Laboratory**

**Preparing the Report** .....: Intertek Testing Services NA Inc.

**Test Specification:**

**Standard**.....: Client Specified Testing

**Date(s) of Testing**.....: 05/12/2026 – 05/13/2026

**Product Description:**

**Product Type:** .....: Guardrail System

**Brand Name:** .....: Frontline Fall Protection Inc

**Model Number(s):** .....: TRG10 Trench Guardrail System

**Model Sharing** .....: N/A

**Date(s) Samples Received** .....: N/A

---

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**TEST REPORT FOR FRONTLINE FALL PROTECTION LLC**

Report No.: 106559921CRT-002

Date: May 15, 2026



**SECTION 1**

**SUMMARY OF TESTING**

TESTS COMPLETED	STATUS
Client Specified Testing Referencing – OSHA 1926.502(b)(3)	SEE RESULTS

**SECTION 2**

This test report concludes the work anticipated in the testing phase of your project. If there are any questions regarding this report please contact the undersigned at 607-753-6711.

<b>COMPLETED BY:</b>	Alex Smith	<b>REVIEWED BY:</b>	Matthew Stevens
<b>TITLE:</b>	Technician	<b>TITLE:</b>	Team Leader
<b>SIGNATURE:</b>		<b>SIGNATURE</b>	
<b>DATE</b>	05/14/2026	<b>DATE:</b>	05/15/2026

Please see attached test data for details.

**SECTION 3**

**TESTING EQUIPMENT CALIBRATION INFORMATION**

USED FOR TEST	DESCRIPTION	MANUFACTURER	CONTROL NO.	MODEL NO.	SERIAL NO.	CAL. DATE	CAL. DUE
X	Load Cell	Interface	L137	-	-	07/16/25	07/16/26

# TEST REPORT FOR FRONTLINE FALL PROTECTION LLC

Report No.: 106559921CRT-002

Date: May 15, 2026

## SECTION 4

### SUPPLEMENTAL TEST DATA

SECTION (TEST)	REQUIREMENT	RESULTS						
Client Specified Testing Referencing: OSHA 1926.502(b)(3)	Guardrail systems shall be capable of withstanding, without failure, a force of at least 200 pounds (890 N) applied within 2 inches (5.1 cm) of the top edge, in any outward or downward direction, at any point along the top edge.	<table border="1"><thead><tr><th>Test Requirements:</th><th>Results:</th></tr></thead><tbody><tr><td>Did Sample withstand a force of 200lbs applied in a outward direction without tipping over?</td><td>YES</td></tr><tr><td>Did Sample withstand a force of 200lbs applied in a downward direction without tipping over?</td><td>YES</td></tr></tbody></table>	Test Requirements:	Results:	Did Sample withstand a force of 200lbs applied in a outward direction without tipping over?	YES	Did Sample withstand a force of 200lbs applied in a downward direction without tipping over?	YES
		Test Requirements:	Results:					
		Did Sample withstand a force of 200lbs applied in a outward direction without tipping over?	YES					
Did Sample withstand a force of 200lbs applied in a downward direction without tipping over?	YES							

## SECTION 5

### REVISION HISTORY

REPORT NUMBER	DATE OF REVISION	DESCRIPTION OF CHANGE:	PROJECT OWNER	REVIEWED BY
106559921CRT-002	05/15/2026	Original Report	Alex Smith	Matthew Stevens

**TEST REPORT FOR FRONTLINE FALL PROTECTION LLC**

Report No.: 106559921CRT-002

Date: May 15, 2026

**SECTION 6**

**PHOTOGRAPH**



**Note:**

Sample tested is photographed (Yellow Guardrail).